POWER

McGraw-Hill Publishing Co., Inc., 330 West 42nd St., New York, N. Y.

GENERAL INDEX TO VOLUME 85

JANUARY–DECEMBER, 1941

January	**Pages 1–72**
February	**" 73–150**
March	**" 151–228**
April	**" 229–304**
May	**" 305–380**
June	**" 381–458**
July	**" 459–536**
August	**" 537–616**
September	**" 617–704**
October	**" 705–784**
November	**" 785–864**
December	**" 865–938**
Mid-December	**" 939–999**

A

ACCIDENTS AND ACCIDENT PREVENTION

Boiler explosion. R. C. Sermon.....*270
Ladder for safe access to boiler drums. Frank Smart *913
Safe loads on wire-rope slings (Power's Data Sheets) *365
Safety cross-over for hot pipes. M. T. Pate *915
Safety practices in elevator maintenance 535c
Safety standards for fixed steel ladders. W. E. Rossnagel..... *28
Safety standards for operating platforms. W. E. Rossnagel.....*329
Stairs designed for safety. W. E. Rossnagel *166

AIR COMPRESSORS

Air receiver outdoors protected by cover. A. R. Ciotti.....*427
Bearing lubrication of reciprocating air compressors. J. I. Clower.....*390
Cooling water does triple duty for laundry. Thomas Wood.....*345
Cooling-water failure gives alarm. H. M. Spring *426
Fires and explosions in compressed-air systems. J. I. Clower..... 269
Guide to better compressor lubrication. J. I. Clower.....*734
Heat-temperature—entropy chart for air (Power's Data Sheets)..... 213
Improvement on cooling-water hookup. E. W. Johnston..... 513
Lubricating cylinders of reciprocating air compressor. J. I. Clower.....*186
Rules of successful air-compressor operation. J. I. Clower..... 201
Water cooling keeps compressor operating *585

AIR CONDITIONING

Air-conditioned power-factor correction (picture feature) 570
Fans for air conditioning. V. C. Finch.*359
Sweets Co. air conditions with exhaust steam. J. G. Berger.....*494
Tulsa, Okla. offices building air conditioned with existing boilers.....*312
American Society of Mechanical Engineers —Fuels Conference *926
American Society of Refrigerating Engineers—New York meeting..... 32
Association of Iron and Steel Engineers— Convention and Exposition.....*845

B

Battelle Memorial Institute meets.....374c

BEARINGS

Indicator for bearing temperatures. E. E. Norman 134
Micarta increases guide-bearing life....*912
Oil-ring scrapers stop bearing heating. Alex Gray *913

BELTS

Belt alignment. Stewart, Relief.....*830
Belt drives *94
Guard to protect V-belts. M. T. Pate.. *49
Longer life from conveyor belts. P. W. Van Orden *339
Pulley alignment makes flat belts run true. James Adams, Jr.....*577
Three ways of maintaining correct belt tension. James Adams, Jr.....*334

BOILERS

Altman's department store increases boiler capacity with "booster".....*176
Blowdown control at boiler front. G. M. Wilson *584
Blowdown pipe held by washout-plug clamp. C. C. Linde.....*351
Blow-down signals. S. H. Coleman....*686
Boiler converted into an economizer. N. T. Pef *49
Boiler-water concentration can be too low. W. L. Starkweather.....*724
Bolstering a foundation under two boilers. J. H. Lym.....*761
Building a typical central-station boiler takes up to two years (chart).....*639
Bulges in watertube boilers prevented. Harry Spring *906
Burlington Station, N. J. adds 100,000-kw. condensing unit. H. Weisberg...*460
Bypass helps clean strainer. C. R. Anderson *675
Chart to calculate boiler ratings used by New York City apartment building. P. E. Meredith.....*420
Combustion control holds steam pressure constant. E. S. Bristol.....*242
Compressed air traces boiler leaks. R. O. Billings *674
Condensate meter *271
Conductivity meters indicate boiler-water carryover or condenser leakage. R. T. Hanlon.....*812
Corrosion prevented in boilers by home-made circulating system for chemically treated water. H. M. Naylor...*386
Cracked boiler head repair. H. M. Spring *675
Crank control for blowoff valves. C. C. Lynde *917
Deaerating heater treats feedwater at Texas Co. topping plant. Flynn & Yoder *554
Determination of solids in boiler water. Smith & Williams.....*189
Draft gages. W. H. Pugsley..... pt. 1, *44; pt. 2, *118; pt. 3, *268
Draft troubles. Brown, Gibbons, Mullen, Simons, Bradley, Atlas, Gozdenovich *831
Electric drill cleans boilers. R. Boettinger *673
Embrittlement problems discussed by A.S.M.E. meeting *978
Explosions of boilers. R. C. Sermon....*270
Flyash reduction. Sumner, Julsrud....*127
Froedtert Grain & Malting modernizes with new boilers.....*548
Furnace data (A.S.M.E. meeting).....*980
Furnaces for wood burning. L. E. Webber *471
Gage glass water level spotted by bottom lighting. C. A. Van Deursen.....*671
Gage glasses backed with painted board. P. E. Meredith.....*582
Handbook of feedwater treatment..*865–896
Haverstraw Industrial Terminal fires with four fuels and automatic control. *25
Hot makeup water reduces corrosion. C. R. Anderson.....*507
Kansas refinery saves by returning part of blow-down to hot-process softener. E. D. Flickinger.....*841
Kearny mercury-turbine-boiler unit sets efficiency record. Smith & Thompson. *236; (Ed) 229
Makeup water reduced 50%. H. P. King *607
Method for determining best CO_2 in boiler plants. R. E. Summers.....*571
Multi-purpose topping unit serves Boone Station, Iowa *563
Natural gas requires firing technique different from oil or coal. R. H. Godeke *560
Orifice in gage glass. Downs, Pef, Mullen, Grant, Armstrong..... *50
Orsat on wheels speeds boiler tests. H. M. Naylor.....*673
Outdoor boiler for Taunton power plant 609a
Peepholes in hrt settings..... 764
Pilot gage for base-load operation. G. I. Smith 751
Practical methods of diesel heat recovery. G. C. Boyer.....*172
Pulverized-fuel-fired boiler kept in service with auxiliary chute. O. M. Roberts *507
Questions for boiler-room engineers.... 150a; 511; *762
Refractory replacement report.....304a
Retubing job solved. S. M. Elonka.....*201
Returning condensate. Smith, deRosa, Mullen, Brock, Newell, Gibbons, Julsrud, Heinze *277
Sawdust and wood waste burns on flat grate in boiler furnace at Herkimer furniture plant *903
Shims around boiler tubes. S. M. Elonka *427
Stud tubes keep boilers working. R. O. Billings *673
Suction-discharge design aids fan performance. Theodore Baumeister, Jr..*286
Telltale holes test pressure-vessels for corrosion. H. M. Spring.....*196
Testing metal-wall thickness. B. M. Thornton *780b
Troubles with high stack temperature. McNally, Cunningham, Equi, Chandler, Brown, Gibbins, Julsrud..... 588
Twin Branch plant has open-pass natural-circulation boiler, rated at 550,000 lb. per hr.....*796
U. S. Dept. of Agriculture Wyndmoor Laboratory secures efficiency with metering and controllers.....*105
U. S. Dept. of Agriculture Wyndmoor Laboratory tests pneumatic-spreader stokers. T. A. Marsh.....*923
Vacuum breaker on boiler.....*675
Vacuum for emergency operation. B. Y. Buckley *672
Vertical tubular boiler upper head repaired by welding. A. G. Wiggins...*835
Volume-quality chart for steam. Humphreys & Markson (Power's Data Sheets) 441
Warning light indicates carryover in steam. Nathan Schnoll.....*348
Water column sampling? N. T. Pef...*929a
When to weld for boiler repairs.....*114
Wrong answer on boiler-tube thickness. 510

C

CABLES

Armored cable, how to cut.....*918
Gas-filled cable for power distribution..997c
Hand rule simplifies rope reeving on drum. Ernest Wellhofer.....*501
How to apply wire-rope clips.....*282
How to detect and cure wire-rope troubles. A. J. Morgan....pt. 1, *81; pt. 2, *169
How to handle wire rope.....*514
Safe loads on wire-rope slings (Power's Data Sheets) *365

CHIMNEYS

Alameda Station replaces corroded stack rings with welded..... *18
Carriage for stack work.....*670
Inspection of stack with binoculars. C. R. Anderson 120
Selecting chimney size for natural draft. J. G. Mingle.....*283
Steam jets for damaged stack. P. F. Keough *671
Clutches *92

COAL

Coal-handling costs for 14 central stations (table) 601
Coal-tower maintenance cut. A. P. Danz 675
Hammer loosens coal in chute.....*672
Handling coal at Buzzard Point extension *306
How America uses bituminous coal 1940 (chart) 635
Pulverized-fuel-fired boiler kept in service with auxiliary chute. O. M. Roberts *507
Systematic operating plan cuts steam heating costs. J. F. Wooley (chart).. 117
Coal, see also Fuel
Combustion—Shortcuts in combustion. Phil Swain *499
Wood burning facts. L. E. Webber.....*156
Communication between stations helped by loud horns added to inter-communicating telephone. G. I. Smith...*915

CONDENSERS

Bronze welding cures leaky condenser. T. B. Jefferson.....*679
Cleaning condensers by reversed water flow. S. H. Coleman.....*751
Three ways to support a condenser. A. J. Braun *790
Tight plugs for condenser tubes. W. M. Kennedy 679

CONTROL

Burlington Station, Public Service Electric & Gas Co., N. J. charts the way for motor-operated valves. S. D. Barr.*900
Columbia University has electrical device which solves heat-transfer problems. P. W. Swain.....*480
Combustion control holds steam pressure constant. E. S. Bristol.....*242
Condenser valve operated by motor drive. H. M. Naylor.....*351
Four fuels for boilers of Haverstraw Industrial Terminal, under automatic control *25
Fuel control for combination burning at Rankin, Pa. plant of Carnegie-Illinois Steel *564

(*) illustrated. (Ed) Editorial

Page

Governing the Pickwick Landing hydro turbines. J. J. Ring.....*822
Heating controls *258
Magnetic variable-speed drives control boiler draft. E. T. Petrik.....*801
Meters guide Delaware Hospital plant operation *745
Motor operation simplifies valve control. C. W. Kuhn.....*468
Report on turbine-governing problems (A.I.E.E. convention) *209
Speed control of plant auxiliaries (Midwest Power Conference).....608a
U. S. Dept. of Agriculture Wyndmoor Laboratory secures efficiency with metering and controllers.....*105
University of Illinois builds a new plant instead of modernizing the old one. Gaffert & Smith.....*322
Voltage control extends motor-speed adjustment. P. W. Arnold.....*178
Warning light indicates carryover in steam. Nathan Schnoll.....*348
Cooling towers—Algona, Iowa, municipal electric-generating station diesel-plant layout. Glenn Boyer.....*786
Skimming pool improves cooling-tower. Elton Sterrett *676

COSTS AND PERFORMANCE

Altman's department store increases boiler capacity with "booster".....*176
Austin Dam plant attains 93% efficiency with adjustable blade turbines. H. V. Terry *326
Coal-handling costs for 14 central stations (table) 601
Diesel engine cost considerations (charts) 405
Ford Motor Co. tests a turbine by the calibrated nozzle method. Dulmage & Walker *476
How to evaluate steam engines as auxiliary drives. E. J. Vonachen.....*595
It takes more steam to heat small hotels. O. E. Stossel.....*502
Owensboro municipal power plant and water-treating station—designed for $1 coal. R. C. Oliver, Jr.....*415
Propeller pumps cut power costs in half for drydock. R. V. Terry..... *22
Republic Rubber saves $3,000 per month with new plant. R. R. Jones..... *2
Steam heating costs cut by systematic operation. J. F. Wooley (chart)..... 117
Couplings, flexible *90

D

Directory of manufacturers for 1942..Mid-Dec.
Drawing board. W. J. Knoll, Jr.....*350
Drawings—how to make "perspective" sketches. Phil Swain.....*825
Dust collection, see Smoke abatement

E

Edwards, George—Don't be a sourpuss!.. 140
Flag Day 444
Get a glory..... 850
How to be happy though married..... 292
Information please 770
Mother O'Leary's cow..... 524
No justice 928
Over-experience 602
Someone else's idea..... 218
Sowing the wind..... 65
Steady, boys! 368
Us little men..... 690
Efficiency of a machine, figuring the. Phil Swain *356
Ejector performance studied.....*982

ELECTRICITY

Air conditioned power-factor correction (picture feature) 570
Ammeter connections on 3-wire generators. S. O. Smith.....*275
Armature core repair. Thomas Wood.*680
Armature core welded to spider. Thomas Wood *272
Blowpipe removes armature insulation. D. C. Olson..... *47
Breakers blast circuits open. R. M. Spurck *9
Capacitors double transmission distance? 228c
Capacitors for power-factor improvement. M. I. Alimansky..pt. 1, *713; pt. 2, *793
Capacitors save $6900 in one year's operation. R. E. Haubury.....*504
Census report shows industrial power plant generation (charts)..... 342
Circuit breakers—oil, oil-poor and oilless. B. P. Baker.....*542
Circuit breakers tested in Westinghouse giant "igloo" *820
Circuit breakers used in cascade.....*699b
Columbia University has electrical device which solves heat-transfer problems. P. W. Swain.....*480
Commutating pole polarity. H. W. Hodgson *349
Commutator connections caused sparking. H. W. Hodgson..... 504
Conductor size selector chart (Power's Data Sheets) 847
Connection upsets load division. R. O. Cummings *425
Copper conductor simplified practice..781a
Copper conductor standards accepted... 597
Corrosion prevention in steel-tank rectifiers 226c

Page

Current-carrying capacity of conductors in amps allowed by the National Electrical Code (Power's Data Sheets).. 519
Diesel generators as synchronous condensers. Roberts, Bailey, Bachmann, Hanratty *508
Electric heater trouble caused by poor contact. R. Boettinger.....*914
Electrical system load-factor chart (Power's Data Sheets)..... 63
Fish-cooker drive has 1000 to 1 speed range *197
Fluorescent lamp troubles. Warren & Keiffer *810
Gearmotors—design, construction and operation *263
General Electric installs jointless square-tubular busbars welded throughout. R. B. Woodruff.....*240
Generator pounding stopped by new key. H. W. Hodgson..... 425
How to grease ball-bearing motors...*358
How to protect motor and generator field coils. S. B. Griscom..... *33
How to synchronize with outside source of power. Waterman, Roberts, Bachmann, Noiles, LeQuesne, Feller, Markland, Schmoker *354
How to synchronize two power systems. James Wilson 695a
Indicating ammeter prevents motor overloads. B. R. Stewart..... 914
Insulation affected by atmospheric changes 227b
Insulation corona killed by semi-conducting paint 699a
Insulations permitted by National Electrical Code. M. M. Brandon.....*496
Loud horns added to inter-communicating telephone. G. I. Smith.....*915
Magnetic variable-speed drives control boiler draft. E. T. Petrik.....*801
Metering boosts efficiency at U. S. Wyndmoor Laboratory *105
Meters guide Delaware Hospital plant operation *745
Millivoltmeter checks oil quality. H. W. Hodgson 688
Motor ball bearings cleaned.....*433
Motor, defective, causes lamps to flicker. H. W. Hodgson..... 424
Motor follows motion of countershaft pulley. L. H. Skougor.....*200
Motor, induction, for wind tunnel, Wright Field *340
Motor maintenance program at Ansonia O. & C. Co.....*41
Motor mounted on ceiling with stacking machine *681
Motor operation simplifies valve control. C. W. Kuhn.....*468
Motor overloads prevented by indicating ammeter. B. R. Stewart..... 914
Motor trouble caused by low voltage. B. R. Stewart..... 350
Motor troubles may be caused by wrong connections 907
Oil circuit breakers operated in cascade. A. L. Bennett.....*839
Prime movers, motors and generators in manufacturing plants (table)..... 623
Re-connection cures transformer troubles. H. W. Hodgson.....*273
Reverse polarity on dc generator cured. H. W. Hodgson.....*123
Roosevelt Irrigation District changes from 25-cycle to 60-cycle power to maintain normal pumping. J. C. Redd *922
Secondary networks for industrial plants 701b
Separate conduits overheat insulation. R. O. Cummings..... 506
Shunt-field connections make a difference. H. W. Hodgson..... 349
Small motor operated from large one. E. L. Hemenway.....*834
Test keeps voltage regulators in shape. William Knoll, Jr.....*681
"Threading" the rotor into the stator..*262
Transformer changes save power. A. R. Markland *680
Transformer corrects lighting trouble. W. T. Estlick.....*681
Transformer for base loads—Hipersil..*522
Transformer noise reduced.....228b
Undersize shaft wrecks large fan. H. W. Hodgson 581
Universal joints speed motor testing. J. L. Fuller.....*424
Voltage control extends motor-speed adjustment. P. W. Arnold.....*178
Water-cooled transformers changed to self-cooling. M. E. Bridston.....*834
Why ac magnet coils may overheat. R. B. Glenn..... 48
Wrong connections unbalance voltage. H. W. Hodgson.....*753

ELEVATORS

How to detect and cure wire-rope troubles. A. J. Morgan....pt. 1, *81; pt. 2, *169
Oldest elevator in the U. S.....*848
Safety practices in elevator maintenance 535c

ENGINEERS

Building a boss (Ed)..... 151
Reminiscences about the old chief. William Doran .....pt. 3, *21; pt. 4, *88; pt. 5, *185; pt. 6, *235; pt. 7, *321; pt. 8, *396; pt. 9, *493; pt. 10, *551; pt. 11, *739; pt. 12, *821; pt. 13, *899
"So you want to be an engineer" (reprint) *310
Skilled manpower stands at the throttle of power supply.....*640

Page

ENGINES—DIESEL AND GAS

Accessory equipment for internal-combustion engines *402
Algona, Iowa, municipal electric-generating station diesel-plant layout. G. C. Boyer.....*786
Census report shows industrial power plant generation (charts)..... 342
Cost considerations (charts)..... 405
Denver & Rio Grande Western R.R. builds diesel streamliners.....700b
Developments in lubrication of gas engines *290
Diesel installed 7 ft. below the floor in Minneapolis Chamber of Commerce building *195
Diesel installations (additional) (table) 519
Diesel installations, typical (table)... 406
Diesel installations under 115 hp. (table) 409
Diesel jacket-water flow chart (Power's Data Sheets) 925
Diesel manufacturers & supplies (list).. 410
Engine performance (charts)..... 401
Flywheel to help hand starting of gas engine. G. M. Wilson.....*424
Gas engine installations (additional) (table) 519
Gas-engine installations under 300 hp. (table) 409
Gas-engine manufacturers & supplies (list) 412
High-temperature cooling affects gas-engine performance *545
High-temperature gas-engine cooling. M. H. Clark.....*515
How oil and gas engines work.....*398
How to make a simple diesel smoke meter. P. H. Schweitzer.....*800
How to make arc-welded steel cylinderheads. F. E. Ford.....*763
How to make and fit piston rings. S. M. Elonka *192
Iowa's largest diesel station uses kerosene to heat fuel. J. M. Drabelle....*332
Locker-plant industry can use diesel and gas engines. Orville Adams.....*593
Lube-oil reclaimer for the diesel plant. H. O. Munson.....*749
Muffler for diesel receiver. A. B. Allen.*678
Multiple muffler reduces exhaust noise. M. T. Pate.....*676
Multiple muffler reduces engine exhaust noise. G. M. Wilson.....*506
Nickey Bros. lumber mill meets power and heating load with diesel-steam plant *718
Northwestern Corp. vending machine manufacturer, depends upon diesel power *36
Oil reservoir for emergency lubrication of gas engine. G. M. Wilson.....*425
Practical methods of diesel heat recovery. G. C. Boyer.....*172
Purification of diesel lube oil. S. S. Hansen.....pt. 1, *14; pt. 2, *78
Quick engine-frame repair. C. O. Hagen *676
Rea Station, La. gas-engine test data gets fine tooth-comb inspection (chart & table) 440
Reducing gear for diesel indication.... *84
Threaded plug repairs diesel piston. Leslie Bradley *678
Water quantities and temperatures in diesel cooling. G. C. Boyer.....*919

ENGINES—STEAM

Breakage of wedge bolts. Wiechmann, Hardy, Heinze, Carter, Corrigan, Spencer, Wyrough, Barrett, Mandeville, Rushenberg, Larson, Woods, Redman, Burton, Doehne..... *51
Figuring steam-engine efficiency. Phil Swain *432
How to figure steam-engine drive. E. J. Vonachen *595
How to make and fit piston rings. S. M. Elonka *192
How to set an engine on dead center...*208
Locomotives supply temporary steam load. S. D. Distelhorst.....*506
Loose crank pin. Greer, Cunningham, Donovan, deRosa, Wyrough, Elder, Bromley *429
More horse power from steam engine. Parkinson, Carter, McNally, Chamberlain, Flowers, Blum, Britt, LeQuesne. 124
Packing troubles in small steam engine cured by lubrication. R. Boettinger..*505
Piston-rod scraper stops oil leakage. R. E. Fontaine *677
Steel rings make unruly governor behave. A. L. Waterman.....*677

EQUIPMENT

Acetylene generator *604c
Air-injection stoker manifold.....529c
Alarm system, flame-failure..... 61
Balancing machine *696a
Base plates *453a
Bearings *138; *3716
Bearing, bronze on steel.....*442
Bearings, porous *605a
Belt, conveyor.....453c; *521; 775a
Belt, high-speed 606b
Belt, multi V.....*295c; *606c
Belting, transmission 291
Blower fan *457a
Blueprint machine *138
Boiler, waste-heat *136
Boiler-water comparator 372a
Breaker operator *294b
Bushings *291
Cabinet, storage *373b
Cable, dead-end *607a
Capacitor, mobile *849

(*) illustrated. (Ed) Editorial

Page

Carrier, pneumatic *455a
Circuit breaker....*138; *296b; *372a; *528b; *606a; *697b
Circuit interrupter 607b
Clamp, bus support....*607b
Cleaner, pipe and tube....*529a
Coal crusher and sampler....*366
Compressor, steam-driven *521
Compressors *453b
Condensers *141a; *853b
Connector....*457a; *696b; *774b
Contactors *136
Control, boiler-water *136
Control, combustion *854a
Control, electronic level....*66c
Control, feeder 853c
Control lenses *528b
Control, liquid level.... 138
Control, photoswitch level....*767
Control, speed *142a
Control, welding....530a; *774b
Controller, flame *291
Controller, proportional *853a
Controller, ratio *521
Controller, recycling 216
Controller, secondary *530a
Controller, temperature *214
Conveying system bulk....*599
Conveyor, vibrating 371c
Cooler, evaporative *852c
Coupling, chain *221a
Coupling, flexible....*61; *372c; *442
Coupling, piloted 773c
Coupling, pipe *530c
Crane stop *67a
Cutter, pipe intersection....*215
Damper *137
Developing machine *294c
Diesel indicator *604c
Diesel, 3-cylinder 452c
Drafting machine 607a
Drill, electric *221a
Drive, adjustable-speed motor....*366
Drum-sealing rings *373a
Electrode selector 773c
Elevator roller guides....*68b
Emergency light and power units....854a
Engine, diesel....*136; *138; 291
Engine, gas *137
Exciter *698b
Fan *530b
Filter, magnetic *66c
Filter, water *222b
Fire extinguisher 442
Firebrick 141c
Floor grating 698b
Flue-rolling machine *216
Fluorescent lamp 61
Fluorescent tester *854b
Frequency converter, electron tube....*67c
Furnace, thermocouple *366
Gage, thickness 293c
Gage, water-level *774a
Gaskets, synthetic 604b
Generator, a.c. *456a
Generator fire protection.... *62
Glass insulation 222a
Governor, isochronous 60
Heater, electric immersion....*697a
Heater, unit....*141c; *214; *295a; *457c
Hoist, portable *137
Hose, air 607a
Hose, metal *849
Humidifier, air-operated *67a
Idler, impact *529b
Idler, return *452c
Indicator, multi-point *136
Indicator, temperature 216; 767
Infra-red lamps 775a
Instrument charts 697c
Insulating fire brick.... 521
Insulation *696b
Insulators 696c
Jumper stick *454a
Lamp fixture 221b
Lamp, indicating *599
Lamp, industrial....*372b; 697c
Lamp, service 528a
Lamp socket, adjustable.... 215
Lamp starter 141b
Light, extension *221b
Light for engineer....*216
Lubricating oil....141b; 291; 442
Lubrication unit *214; 599
Lubricator, automatic *295c
Lubricator, forced-feed *453c
Metal, sensitized 295b; 599
Metallizing gun *372a
Meter, frequency *62
Meter, fuel-oil *529c
Motor *296c
Motor, capacitor *371b
Motor, d.c. *61
Motor, explosion-proof *530b
Motor, induction *141a
Motor, reversing *767
Motor, splashproof *457c
Multi-breaker 696c
Nozzle, atomizing *521
Nozzle, humidifying *68a
Nozzle, spray 296c
Nut, lock *60, *62
Nut, stop 457b
Oil burner *68a
Oil filter *698b
Oil tank cleaner....605c
Oiler, dust-proof *291
Oxygen recorder *215
Packing 775a
Packing, plastic *68a
Packing, spiral 372c
pH indicator 607b
Photometer *454b
Pillow blocks *773c
Pipe cleaner 453a
Pipe hangers and vibration eliminators.*599
Pipe coupling *697b
Pneumatic mechanisms for circuit breakers *456a

Page

Porcelain, electrical 294b
Power float and tamp....*453c
Printing machine *220c
Pulley coating of liquid rubber....373b
Pulley, variable-speed 295b
Pump, air 530b
Pump, centrifugal....*221c; *455b
Pump, chemical *62; 138
Pump, explosion-proof 372c
Pump, glass 295c
Pump head *60
Pump, air-powered *774c
Pump, horizontal *697a
Pump, plastic *221c
Pump, power *853b
Pump, rotary....*67b; *456c
Pump, sump *455c
Pump, turbine....606a; *853c
Pump, vacuum pressure....*604b
Pump, vane-type *849
Pushbutton station 372b
Recorder 697c
Recorder, dissolved oxygen.... *60
Recorders, dc 60
Recording charts 296a
Rectifier, spot welding....*373a
Reducing elbows *294a
Regalvanizing process 849
Regulator, air-cooled *220b
Regulator, temperature 220c
Regulator, voltage....*61; *220b; *295a
Relay *606b
Relay, distance 605b
Relay, temperature 296c
Resistors 456b
Review of power and mechanical equipment *940–970
Rheostat, generator *214
Ring compressor *605c
Rubber, conductive 216
Scales, coal *605b
Sheave, detachable *215
Smoke alarm for boiler room....455a
Smoke detector 605b
Starter, combination....*528a; *530c
Starters, motor *68c
Stoker, chain-grate *366
Strainer *67a
Switch, cam limit....*142a
Switch, float *216
Switch, photo-electric *453b
Switch, starter 852c
Switch, time delay....*529a
Switchgear, metal-clad 605c
Synthetic coating 698c
Tachometer 222a; *696c
Tachometer, hand....*456b; *457b
Tear-off device *293c; *529b
Terminal strips *697c
Thermo drain *141b
Thermometer, indicating-recording *61
Thermometer, transparent *137
Torch holder *774c
Trailer, welding 774c
Transformer *294a; *696c
Transmitting system 607a
Trap, steam....*457b; 530c
Trap, vacuum *531a
Truck, cylinder *294c
Tube-coating machine *222a
Vacuum cleaner *371c
Valve, butterfly *442
Valve, combined trip and throttle....*442
Valve, gate 137
Valve, manual reset....*454c
Valve, micro-action *452c
Valve, reducing 696a
Valve-stem alloy *296a
Valve, swing check....373b
Variable-speed test rig....*216
Vise, hydraulic *849
Vise bracket *455a
Vise stand 296b
Vulcanizer *767
Water heater *606b
Waterproofing compound....521; 854b
Welder, arc....*454b; *606c; *767; 853a
Welding ring *455b
Welding rods 61
Whiteprint machine *774a
Wrench, impact *767

F

FANS

Air conditioning fans. V. C. Finch....*359
Draft fans kept in good shape.... 475
Fan performance aided by suction-discharge design. Theodore Baumeister, Jr. *286
Fan-power needs important consideration. S. H. Coleman....150c
Undersize shaft wrecks large fan. W. H. Hodgson 581
Federal Power Commission—New statistical survey 861a

FEEDWATER

Atomic hookups 884
Blowdown *880
Carbonate and sulphate hardness colloids, oil *874
Chemical building blocks....*885
Cold lime-soda and hot-process softening *870
Common compounds 886
Corrosion prevented in boilers by home-made circulating system for chemically treated water. H. M. Naylor..*386
Deaerating heater treats feedwater at Texas Co. topping plant. Flynn & Yoder *554
Deaerators, open heaters, evaporators..*878
Determination of solids in boiler water. Smith & Williams....*189

Page

Double screen keeps water clean. Alex Gray *585
Dravo Corp. boiler plant served by multi-purpose feedwater system....*111
Embrittlement problems discussed by A.S.M.E. meeting *978
Equipment, tests, consultation, chemicals 882
Every-day control tests.... 894
Filter removes oil from exhaust. Frank Smart *686
Fixing method speeds oxygen test. Bill Maddock *686
Handbook of feedwater treatment..*865–896
Hot makeup water reduces corrosion. C. R. Anderson....*507
Improved pH test for boiler water. L. I. Pincus 582
Kansas refinery saves by returning part of blow-down to hot-process softener. E. D. Flickinger....*841
Meaning of water analysis.... 895
Miniature sulphur burner treats feedwater at Necco. G. A. Johns.... *57
Open feedwater heater operation. Fred Schubert *346
Phosphoric acid controls alkalinity. S. H. Coleman 836
Piping change holds feed temperature. H. P. King....*687
Sampling equipment for feedwater. D. K. French *743
Scale, corrosion, carryover, embrittlement 866
Screen feedwater chemicals....*687
Sedimentation, coagulation, filtration, silica removal *868
Silica, corrosion, carryover, embrittlement *876
Typical reactions of water treatment... 888
Useful chemical data (table).... 896
Zeolite—base-exchange and hydrogen-exchange *872

FIRE PROTECTION

Devil's ally 705
Fighting power-plant fires. W. E. Rossnagel....pt. I, *804
Know and understand fire—to control it effectively. H. W. Lange....*720
Operating engineers enlist for defense fire protection *423
Fires and explosions in compressed-air systems. J. I. Clower.... 269

FOREWORD

Building a boss.... 151
The devil's ally.... 705
Guide for 1942.... 939
Let's be proud.... 459
Long war or short? take your choice— 897
Mercury-steam epic 229
The most important months.... 1
One hundred days.... 305
Pioneering in wind power.... 381
Success with 2500 lb.... 785
365 days of emergency.... 73
What about power shortage?.... 537
Foundation under two boiler is bolstered without interfering with production. J. H. Lym....*761

FUEL

Application of control principles made to a woodburning furnace. R. E. Summers *571
Coal, pitch, tar or oil fuel for boilers of Haverstraw Industrial Terminal, under automatic control.... *25
Consumption of fuel by industry—1939 (table) 622
Fuels Conference of A.S.M.E. and A.I.M.M.E. *926
Furnaces for wood burning. L. E. Webber *471
Gas and pulverized coal burned at single-turbine plant of Carnegie-Illinois Steel, Rankin, Pa....*564
Hints on burning natural gas. R. H. Godeke *560
How America uses bituminous coal, 1940 (chart) 635
How America uses natural gas (chart). 634
Iowa's largest diesel station uses kerosene to heat fuel. J. M. Drabelle....*332
Nicky Bros. lumber mill fires boilers with sawdust and shavings....*718
Oil fields location (map).... 633
Pratt, Read & Co. saves by turning wood shavings into steam. W. W. Gaylor *393
Removing water from fuel oil. Mullen, Brown, Naylor, Corrigan, Hicks....*428
San Francisco steam plants, built next to three oil refineries, use oil waste for fuel *538
Sawdust and wood waste burns on flat grate in boiler furnace at Herkimer furniture plant *903
Total petroleum products 1940 (chart).. 632
Transportation struggles to meet peak fuel needs (charts).... 632
Warmed butane line saves fuel costs. G. M. Wilson....*504
Where industry's fuel goes (chart).... 623
Wood burning facts. L. E. Webber....*156
Wood-waste and pulverized coal burned by Heywood-Wakefield. K. R. Warrington *37

G

Governors—Steel rings make unruly governor behave. A. L. Waterman....*677

(*) Illustrated. (Ed) Editorial

Page

H

Heat—How heat behaves. L. N. Rowley..*245
Temperature-entropy chart for air (Power's Data Sheets)..... 213

HEAT BALANCE

Booster pump increases spray-pond capacity. S. H. Coleman.....*507
Republic Rubber installs new equipment, reduces costs, secures heat balance. R. R. Jones..... *2
Standard form for turbine heat balance. E. V. Pollard.....*435
Heat exchangers—Cleaning heat exchangers. J. M. Drabelle.....*438
Heat transfer—Columbia University has electrical device which solves heat-transfer problems. P. W. Swain.....*480
How heat moves. Phil Swain....pt. 1, *758; pt. 2, *838

HEATING AND VENTILATING

Eldorado Apartments, New York City, power and heating plant operation. P. E. Meredith..... 420
Fans for air conditioning. V. C. Finch.*359
Figuring water heating. Phil Swain...*512
Hanging unit heaters. R. Boettinger..*24
Heating systems *250
How buildings lose heat.....*246
How to figure heat loads.....*248
How to figure heat mixtures. Phil Swain 590
How to select and install unit heaters.. pt. 2, *6
How to ventilate. Holman, Brown, McBurney, McNally, Bachmann, Donovan, Gibbons, Schenk, Butcher, Barrett, Greer *908
It takes more steam to heat small hotels. O. E. Stossel.....*502
Modern heating equipment.....*252
Nickey Bros. Lumber mill meets power and heating load with diesel-steam plant *718
Operation and maintenance of heating systems 260
Parkchester heating plant serves 1,000 family housing project.....230; *261
Pennsylvania Industrial School power plant supplies steam and electricity all year. R. A. Langworthy.....*486
Piping and control for unit heaters, *108; correction 270
Reversed-cycle heating system's operations at the United Illuminating Co..*557
Systematic operating plan cuts steam heating costs. J. F. Wooley (charts). 117
Testing radiator traps. P. E. Meredith..*912

HIGH PRESSURES AND TEMPERATURES

Henry Disston & Sons completes new boiler house designed for high-pressure operation. Samuel Blum.....*730
High-pressure boiler-feed pumps. I. J. Karassik.....pt. 1, *159; pt. 2, *318
High-temperature cooling affects gas-engine performance *545
Scovill Mfg. tops its top—modernizes with 660-lb. 750-F.....*806
Stress calculation for high-temperature piping. S. W. Spielvogel.....pt. 1, *12; pt. 2, *85
Telltale holes test pressure-vessels for corrosion. H. M. Spring.....*196
Testing metal-wall thickness. B. M. Thornton *780b
Hitches, how to make. W. E. Rossnagel..*759
Horsepower—Prime-mover Horsepower in manufacturing establishments (charts, table) 620

I

INSPECTION AND MAINTENANCE

Ball bearings on motors reconditioned..*433
Bench, portable work, built by welding. J. F. Maher.....*583
Blowpipe removes signature insulation. D. C. Olson..... *47
Breakage of wedge bolts. Wiechmann, Hardy, Heinze, Carter, Corrigan, Spencer, Wyrough, Barrett, Mandeville, Rushenberg, Larson, Woods, Redman, Burton, Doehne..... *51
Cleaning heat exchangers. J. M. Drabelle *438
Crankpin loose in engine-generator. Gibbons, Stevenson, O'Brien, Greer, Totten, Schweer *352
Curing cranky crankpin. P. M. Van Wingen *837
Detecting invisible cracks in metal. F. V. Faulhaber 750
Draft fans kept in good shape..... 475
Drills with support are stronger. S. M. Elonka *349
Electric drill cleans boilers. R. Boettinger *673
Gate valve disks and seats reconditioned. Leslie Bradley *426
Generator pounding stopped by new key. H. W. Hodgson..... 425
Hoist handles transformer radiators. E. M. Buitrago.....*199
How to cut rivets with a blowpipe.....*130
How to detect and cure wire-rope troubles. A. J. Morgan.....pt. 1, *81; pt. 2, *169
How to find center of a circular plate. H. M. Spring..... *47
How to keep from losing tools. W. K. Knoll, Jr. *272

Page

How to make and fit piston rings. S. M. Elonka *192
How to set piston valves. S. M. Elonka.*343
How to sharpen glass cutters. Alex Gray *46
Loose crank pin. Greer, Cunningham, Donovan, deRosa, Wyrough, Elder, Bromley *429
Model maintenance schedule laid out for Walk-Over Shoe plant. H. A. F. Campbell *829
Motor maintenance program at Ansonia O & C Co.....*41
Oil and oily waste saved by wringer. H. O. Munson *914
Old packing protects the new. R. Beottinger *279
Old V-belt makes lamp-cord support. Frank Bentley *72c
Pattern for glass disks. G. L. Olsen.... 584
Penetrating oil has maintenance aid. S. H. Coleman 674
Pipe sections make pipe-bending device. C. C. Lynde.....*425
Pipe tee repair. E. M. Elonka.....*48
Pump bearing adjustment.....*120
Pump-cylinder liners trued in a lathe. S. M. Elonka..... *46
Putting micrometer precision into machine leveling. N. L. Rea.....*580
Quick change handle for blade tools. C. H. Willey..... *46
Removing broken studs. T. B. Jefferson *678
Reversed valve rod cures packing trouble. Anthony Greer..... 912
Rubber hose protected by shellac and tape. W. E. Warner..... 834
Sawdust for stopping leaks in a condenser. S. M. Elonka.....*274
Soldering terminals on tubing.....*840
Telltale holes test pressure-vessels for corrosion. H. M. Spring.....*196
Testing spares for defense loads. S. H. Coleman 671
Too much clearance causes packing trouble. Alex Gray.....*582
Valve operation tool. G. C. Willey....*72d
Vee-end chisel cuts cylinder liner. Alex Gray *750
Water cracks journal-bearing surface. F. L. Berry..... 121
Wood block for punch work. C. H. Willey *913
Wrench subdues tough nuts. S. M. Elonka *583

INSTRUMENTS

Accurate measurement of pulsating flow. William Melas *379c
Better visibility for gage glasses. P. E. Meredith *582
Bottom lighting spots water level. C. A. Van Duersen.....*671
Conductivity meters indicate boiler-water carry-over or condenser leakage. R. T. Hanlon.....*812
Home-made condensate meter.....*271
Indicating ammeter prevents motor overloads. B. R. Stewart..... 914
Indicator for bearing temperature. E. E. Norman 134
Level with gage added. R. W. Haines..*917
Meters guide Delaware Hospital plant operation *745
Micrometer simplifies leveling job. R. Boettinger *835
Plastic covers eliminate panel-meter glare. Ulmer & Kerstein.....*740
Putting micrometer precision into machine leveling. N. L. Rea.....*580
Rubber mountings correct meter readings. R. E. Powers.....*581
Self-registering air-gap gage. R. O. Cummins *753
Tin cans, glass tubes make draft gages. T. D. Oswald.....*505
U. S. Dept. of Agriculture Wyndmoor Laboratory secures efficiency with metering and controllers.....*105
Instruments, see also Electricity
Insulations permitted by National Electrical Code. M. M. Brandon.....*496
Inventions wanted for defense. E. S. Smith *418

K

Knots, how to tie. W. E. Rossnagel.....*591

L

Labor—Shift schedule for 4-crew set-up.. 490
Ladders, safety standards for. W. E. Rossnagel *28

LIGHTS AND LIGHTING

Emergency lights from control battery. R. H. Sogard.....*680
Flexible mounting increases lamp life. M. T. Pate.....*584
Fluorescent lamp troubles. Warren & Keiffer *810
Lamp extension cord made more useful. R. Boettinger *122
Reel takes up lamp-cord slack. B. R. Stewart *122
Locomotives supply temporary steam load. S. D. Distelhorst.....*506

LUBRICATION

Bearing lubrication of reciprocating air compressors. J. I. Clower.....*390

Page

Corrosion resistance of modern turbine oils. Wilson, Von Fuchs & Edlund...*162
Developments in lubrication of gas engines *290
Guide to better compressor lubrication. J. I. Clower.....*734
Heater for lubricating oil. G. M. Wilson.*836
How to grease ball-bearing motors.....*358
Insulated oil-pipe joint stops sludging. J. D. Oswald.....*688
Lube-oil reclaimer for the diesel plant. H. O. Munson.....*749
Millivoltmeter checks oil quality. H. W. Hodgson 688
Oil cleaner. S. M. Elonka.....*689
Oil cup solves lubrication problem. J. F. Maher *689
Oil leak stopped. T. C. Cheatham..... 688
Oil reservoir for emergency lubrication of gas engine. G. M. Wilson.....*425
Packing troubles in small steam engine cured by lubrication. R. Boettinger..*505
Penetrating oil as maintenance aid. S. H. Coleman 674
Purification of diesel lube oil. S. S. Hansen.....pt. 1, *14; pt. 2, *78
Quality in a lubricant. C. H. Bromley..*131
Reciprocating air compressor lubrication. J. I. Clower.....*186
Splash-dipper cures bearing trouble. C. H. Willey *688
Turbine-bearing oil leak stopped. T. C. Cheatham *689
Wanted — bearing-lubrication data (A.S.M.E. meeting) 982
Wanted—a new turbine-oil test. M. D. Baker *314

M

Manufacturers directory for 1942....Mid-Dec.
Marine—Back in the days of the old chief. T. G. Hicks..... 288
Power oddity *45
Materials handling—Hoist handles transformer radiators. E. M. Buitrago....*199
Mercury unit at Kearny sets efficiency record. Smith & Thompson....*236; (Ed) 229
Mercury-vapor process history reviewed. (A.S.M.E. meeting) *973
Midwest Power Conference—Chicago meeting *362
Missouri Valley Electrical Assn. meeting..374b
Modernization—Boiler-room modernization for Froedtert Grain & Malting Co. L. A. Corwin *548
Consolidated Edison obtains more kw. from old turbines by rebuilding them. E. Zetterquist *710

N

National Association of Power Engineers—Baltimore convention *765

NATURAL GAS

Analysis chart for natural gas (Power's Data Sheet) 135
Hints on burning natural gas. R. H. Godeke *560
How America uses natural gas (chart). 634

O

Oil burners—Cleaning rig for oil burners.*672
Rebuilt orifices cure burner trouble. A. Honore *671
Orifices, figuring. Phil Swain.....*206
Orsat—Boiler tests with orsat on wheels. H. M. Naylor.....*673

P

Paint-selector guide (Power's Data Guide) 598

PIPING

Beveling pipe with portable machine. Thorns & Marjie.....*274
Brass plates identify valves. S. H. Coleman *584
Burlington Station, Public Service Electric & Gas Co., N. J. charts the way for motor-operated valves. S. D. Barr *900
Chain and spring make simple pipe hanger. T. K. Holmen.....*837
Clamp aligns pipe for welding. T. F. Leach *684
Color code for piping systems (Power's Data Sheets) *766
Color comes to Lincoln Park. L. A. Rogers (poem) 184
Figuring orifices. Phil Swain.....*206
Flow chart for V-notch weir (Power's Data Sheets) 289
Flow measurement. Phil Swain.....*280
L. H. Gilmer Co. installs aeration and filtration plant to clear piping of cooling-water system. Case & Alling....*474
Heating systems *250
Model test checks pipe-stress calculation. S. W. Spielvogel.....*716
Pipe sections make pipe-bending device. C. C. Lynde.....*425
Pipe-threading machine. G. T. White.*837
Piping change improves valve operation. John Platt.....*683
Power threader uses die stocks. H. P. Cleary *350

(*) illustrated. (Ed) Editorial

Page

Preventing corrosion of pipe threads. S. H. Coleman 200
Quick pipe-fitting repair. S. M. Elonka 685
Removing condensate from a steam line. J. O. G. Gibbons *149c
Repair for pipe tee. E. M. Elonka *48
Roller bearing supports pipeline. S. L. Huffman *48
Roller pipe support made by welding. A. L. Bennett *685
Six miles of welded piping in Cleveland municipal power plant *898
Steam ejector from fittings. C. O. Hagen *585
Stress calculation for high-temperature piping. S. W. Spielvogel ... pt. 1, *12; pt. 2, *85
These drain nipples don't break off. S. M. Elonka *678
Unit heaters—piping and control, *108; correction 270
Welding repairs high-pressure lines *683
Will pipe cleaning pay? Allen, Tufft .. 276
Plastic covers eliminate panel-meter glare. Ulmer & Kerstein *740
Platforms, safety standards for operating. W. E. Rossnagel *329
"Power"—Wins award for editorial excellence 858a

POWER PLANTS—STEAM

Alameda Station replaces corroded stack rings with welded *18
Altman's department store increases boiler capacity with "booster" *176
Boone Station, Iowa Electric Light & Power, is served by multi-purpose top *563
Boston Edison, L Street Extension, installs second topping unit to meet loads *485
Burlington Station, N. J. adds 100,000-kw. condensing unit. H. Weisberg .. *460
Buzzard Point extension's coal handling *306
Carnegie-Illinois Steel Corp. expands at Rankin, Pa. *564
Central stations installed or under construction since July, 1940 (table) 654
Central-station steam power map—existing stations with planned capacity. *649
Central-station steam units going in 1941-46 (table) 631
Chicago sewage-treatment works—magnetic variable-speed drives control boiler draft. E. T. Petrik *801
Delaware Hospital, Wilmington, Del. meters guide plant operation *745
Henry Disston & Sons completes new boiler house designed for high-pressure operation. Samuel Blum *730
Dravo Corp. boiler plant served by multi-purpose feedwater system *111
Eldorado Apartments, New York City, power and heating plant operation. P. E. Meredith *420
Federal Power Commission reports basic data for defense power needs (table & charts) 152
Federal Power Commission waives industrial power jurisdiction 700c
Ford Motor Co. tests a turbine by the calibrated nozzle method. Dulmage & Walker *476
Gates Rubber Co. installs a turbine-generator (picture feature) 106
Gorgas steam station to add unit *547
Heywood-Wakefield burns wood-waste and pulverized coal. K. R. Warrington *37
Hutsonville turbine-generator *161
Industrial steam plants installed or under construction since July, 1940 (table) 654
Institutional steam plants installed or under construction since July, 1940 (table) 669
Kearny mercury-turbine-boiler unit sets efficiency record. Smith & Thompson *236; (Ed) 229
Lansing's Ottawa St. Station betters heat rate of most good utility plants. R. F. Cummings *74
Locomotives supply temporary steam. S. D. Distelhorst 670
Mercury-vapor process history reviewed (A.S.M.E. meeting) *973
Montaup Station's topping turbine will bring down heat rate 31
Municipal steam plants installed or under construction since July, 1940 (table) 660
Naugatuck Chemical replaces obsolete boilers by complete new plant *706
Nickey Bros. lumber mill meets power and heating load with diesel-steam plant *718
Oswego's new turbine generator *320
Owensboro municipal is a combination power plant and water-treating station. R. C. Oliver, Jr. *415
Parkchester heating plant serves 12,000-family housing project *230; *261
Pennsylvania Industrial School power plant is built to be economical and dependable. R. A. Langworthy *486
Pratt, Read & Co. saves by burning wood shavings. W. W. Gaylord *393
Republic Rubber replaces boiler, installs mixed pressure extraction turbine-generator. R. R. Jones 2
St. Mary's Hospital, San Francisco, orders new power unit 613c
San Francisco Pacific Gas & Electric builds three steam plants next to three oil refineries *538
Scovill Mfg.'s 139-year record shows progress from "horse" power to high-pressure steam *818

Page

Scovill Mfg. tops its top—modernizes with 660-lb., 750 F *806
Standard Furniture Co.'s Herkimer plant burns sawdust and wood waste. *903
Steam ejector from fittings. C. O. Hagen *585
Sweets Co. air conditions with exhaust steam. J. G. Berger *494
Texas-New Mexico Utilities Co. tests firing technique of natural gas. R. H. Godeke *560
Texas Co., Port Arthur, treats feedwater with deaerating heater. Flynn & Yoder *554
Toronto station of Ohio Edison adds 35,000 kw. (picture feature) 666
Twin Branch plant of American Gas & Electric—design and operation *796
United Illuminating Co.'s experience with a reversed-cycle heating system. *557
U. S. Bureau of Reclamation proposed program of new steam and hydro installations (table) 691
U. S. Dept. of Agriculture Wyndmoor laboratory secures efficiency with metering and controllers *105
U. S. Dept. of Agriculture Wyndmoor laboratory tests pneumatic-spreader stokers. T. A. Marsh *923
University of Illinois builds a new plant instead of modernizing the old one. Gaffert & Smith *322
Venice station, St. Louis, first unit nearly complete 723
Venice Station No. 2 of Union Electric Co. described at A.I.E.E. convention. 859c
Watts Bar steam plant to be on line 18 months after authorization. Rich & Mathews (map) 843

POWER SERVICES

Altman's department store increases boiler capacity with "booster" *176
Census report shows industrial power plant generation (charts) 342
Central-station capacity of the U. S. in 1939 (chart) 624
Cooling water does triple duty for laundry. Thomas Wood *345
Henry Disston & Sons completes new boiler house designed for high-pressure operation. Samuel Blum *730
Dravo Corp. boiler plant served by multi-purpose feedwater system *111
Eldorado Apartments, New York City, power and heating plant operation. P. E. Meredith *420
Ford Motor Co. tests a turbine by the calibrated nozzle method. Dulmage & Walker *476
Heywood-Wakefield, furniture manufacturer, burns wood-waste and pulverized coal. K. R. Warrington *37
It takes more steam to heat small hotels. O. E. Stossel *502
Lansing's Ottawa St. Station centralizes controls of boilers, heat balance, steam and electric output. R. F. Cummings *74
Naugatuck Chemical replaces obsolete boilers by complete new plant *706
Nickey Bros. lumber mill meets power and heating load with diesel-steam plant *718
Parkchester heating plant serves 12,000 family housing project *230; *261
Pennsylvania Industrial School power plant supplies power for workshops, heating and lighting. R. A. Langworthy *486
Practical methods of diesel heat recovery. G. C. Boyer *172
Pratt, Read & Co. saves by burning wood shavings. W. W. Gaylord *393
Sweets Co. air conditions with exhaust steam. J. G. Berger *494
Reversed-cycle heating system's operations at the United Illuminating Co. .*557
Scovill Mfg. tops its top to meet the present emergency *806
Twin Branch plant of American Gas & Electric—design and operation *796

POWER SUPPLY

Central-station steam power map—existing stations with planned capacity. *649
Distribution of power resources (map) 628
Distribution of power use (chart) 621
The groundwork for the job ahead *648
Installed generating capacity and peak load of public supply plants (chart) 627
Kilowatts win the modern war 617
Kwhr sales for large light and power use (chart) 627
New central-station steam units going in 1941-46 (table) 631
New kilowatts outrace power shortage (chart) 630
The power America had when Hitler took France (chart) 624
Power shortage ..... (Ed) 537
Power supply for industry—1939 (table) 620
Prime-mover horsepower in manufacturing establishments (chart) 621
Public power supply in the U. S. 1940 (charts) 626

POWER TRANSMISSION

Bearings and hangers *102
Chain drives *98
Fish-cooker drive has 1000 to 1 speed range *197
Gear drives *103
Gear teeth don't roll. J. I. Clower 299b
How to evaluate steam engines as auxiliary drives. E. J. Vonachen *595

Page

Longer life from conveyor belts. P. W. Van Orden *339
Magnetic variable-speed drives control boiler draft. E. T. Petrick *801
Mechanical power transmission. F. A. Annett *89–104
Motor follows motion of countershaft pulley. L. H. Skougor *200
Pulley alignment makes flat belts run true. James Adams, Jr. *577
Rope drives *97
Three ways of maintaining correct belt tension. James Adams, Jr. *334
Variable-speed transmissions *99

POWER'S DATA SHEETS

Color code for piping systems *766
Conductor size selector chart 847
Current-carrying capacity of conductors in amps allowed by the National Electrical Code 519
Diesel jacket-water flow chart 925
Electrical system—factor chart 63
Flow chart for V-notch weir 289
Heat-temperature — entropy chart for air 213
Natural-gas analysis chart 135
Paint-selector guide 598
Safe loads on wire rope slings *365
Volume-quality chart for steam. Humphreys & Markson 441
Pressures, how to figure. Phil Swain *55

PUBLIC UTILITIES

Alameda Station replaces corroded stack rings with welded *18
Algona, Iowa, municipal electric-generating station diesel-plant layout. Glenn Boyer *786
Boone Station, Iowa Electric Light & Power, is served by multi-purpose top *563
Boston Edison, L Street Extension, installs second topping unit to meet loads *485
Burlington Station, N. J. adds 100,000-kw. condensing unit. H. Weisberg .. *460
Central-station capacity of the U. S. in 1939 (chart) 624
Central stations installed or under construction since July, 1940 (table) 654
Central-station steam power map—existing stations with planned capacity. *649
Coal-handling costs for 14 central stations (tables) 601
Consolidated Edison obtains more kw. from old turbines by rebuilding them. E. Zetterquist *710
Federal Power Commission reports on additional generating capacity for 1941 ..... 458h
Iowa's largest diesel station uses kerosene to heat fuel. J. M. Drabelle *332
Kentucky Utilities System plans new steam electric plant 31
Lansing's Ottawa St. Station betters heat rate of most good utility plants. R. F. Cummings *74
Manchester station of Public Service of New Hampshire adds unit 616a
Municipal steam plants installed or under construction since July, 1940 (table) 660
Montaup Station's topping turbine will bring down heat rate 31
New central-station steam units going in 1941-46 (table) 631
Oil, oil-poor and oilless circuit breakers. B. P. Baker *542
Oswego No. 2 plant placed in service .. *722
Owensboro municipal is a combination power plant and water-treating station. R. C. Oliver, Jr. *415
Pacific Gas & Electric builds three steam plants next to three oil refineries *538
Public power supply in the U. S. in 1940 (charts) 626
Rea Station, La. gas-engine test data gets fine tooth comb inspection (chart & table) 440
Southwark Station, Philadelphia, to have self starting turbines 544
Statistical utility yardstick 859a
Taunton power plant orders outdoor boiler 609a
Texas-New Mexico Utilities Co. tests firing technique of natural gas. R. H. Godeke *560
Twin Branch plant of American Gas & Electric—design and operation *796

PUMPS

Adjustment of pump bearings *120
American Society of Mechanical Engineers discusses pump performance .. *975
Automatic pump-pressure regulator. G. M. Wilson *683
Booster pump helps deepwell pump when refrigeration demand is at peak. F. A. Kristal *682
Booster pump increases spray-pond capacity. S. H. Coleman *507
Broken stuffingbox repair. Alex Grey .. *682
Capacities of a pump at high temperatures. F. S. Kristal *123
Comparison of spur- and herringbone-gear rotary pumps. W. A. McGrath .. *552
Concrete casing keeps pump going. T. D. Oswald 683
Excessive speed causes pump troubles. F. A. Kristal *753
Grille protects pump lubricator. M. T. Pate *122
High-pressure boiler-feed pumps. I. J. Karassik ..... pt. 1, *159; pt. 2 *318

(*) illustrated. (Ed) Editorial

Page

How to improve parallel pump operation. Bachmann, McNally, Ward, McDonald 754
Metal-disk strainer protects pump. S. M. Elonka *120
Motor pump applied to sump service. F. A. Kristal.....*915
Parallel pump operation. N. T. Pef.... 917
Plate simplifies installation work. G. M. Wilson *751
Practical pumping pointers. F. A. Kristal *727
Priming the pump. DeRosa, Feller, Hicks, Schenk, McDonald, Mullen... 586
Propeller pumps cut power costs in half for drydock. R. V. Terry..... *22
Pump for cooler. Bachmann, McDonald, Wyrough, Naylor, Brown, Gibbons, Greer *202
Pumps lose suction. Gibbons, Blessing, Wright, McDonald, Irwin, Bachmann, Karassik, Equi, Schmidt, Butcher...*910
Repaired with metal spray. Orville Hoksch 685
Roosevelt Irrigation District changes from 25-cycle to 60-cycle power to maintain normal pumping. J. C. Redd *922
Sump-pump control. Thomas Wood....*121
Sump size affects pump efficiency.....861c
Tests show effect of suction head on condensate pumps. H. T. Waldo....*483
Wire-rope guys cure vibration. C. C. Lynde *349
Worn bearings reduce capacity. H. W. Hodgson 582

R

REFRIGERATION

Aluminum alloys commonly used in refrigeration (A.S.R.E. meeting)..... 32
Corrosion in cooling coils. Sterrett, Finch, Bachmann *509
Engines for locker-plant power. Orville Adams *593
Purging ammonia system. McNally, Constable, Jones, Addison, Rea, Blum, Harvey, Elliott, Irwin, Simons, Sanders, Bachmann, Carey..... 755
Reversed-cycle heating system's operations at the United Illuminating Co..*557
Research—Future power pattern is shaped by research *644
U. S. Dept. of Agriculture Wyndmoor Laboratory described *105; *923

S

Short questions and quick answers....54, 511
Sketches, how to make. Phil Swain.....*825

SMOKE ABATEMENT

Dust collectors put old stacks to work. J. E. Watson.....*815
Flyash reduction. Sumner, Julsrud....*127
How to make a simple diesel smoke meter. P. H. Schweitzer.....*800
St. Louis smoke in hand.....458g
Smoke troubles. Baldwin, Gorrie, Stocker, Bradley, Grover.....*205
Stairs designed for safety. W. E. Rossnagel *166
Steel—Production in U. S. to reach 99 million tons 803

STOKERS

Burning law-ash coals on chain-grate stokers. R. M. Garrett.....*674
Draft gages. W. H. Pugsley.....pt. 1, *44; pt. 2, *118; pt. 3, *268
Pneumatic-spreader stokers tested at U. S. Dept. of Agriculture laboratory. T. A. Marsh.....*923

T

Telephone booth in turbine room is soundproofed. George Metz.....*723
Transportation struggles to meet peak fuel needs (charts) 632

TURBINES—DIESEL AND GAS

Portable power from gas turbines. Dr. J. T. Rettaliata.....*266

Page

TURBINES—STEAM

Burlington Station, N. J. adds 100,000-kw. condensing unit. H. Weisberg...*460
Consolidated Edison obtains more kw. from old turbines by rebuilding them. E. Zetterquist *710
Corrosion resistance of modern turbine oils. Wilson, Von Fuchs & Edlund...*162
Ford Motor Co .tests a turbine by the calibrated nozzle method. Dulmage & Walker *476
Installing an industrial turbine-generator at Gates Rubber Co. (picture feature) 106
It takes over two years to put a typical large turbine on the line (chart).....*636
Mercury unit at Kearny sets efficiency record. Smith & Thompson.....236; (Ed) 229
Montaup Station's topping turbine will bring down heat rate..... 31
Plugged nozzle improves efficiency. R. E. Fontaine 677
Report on turbine-governing problems. (A.I.E.E. convention) *209
Scovill Mfg.'s 130-year record shows progress from "horse" power to high-pressure steam *818
Shaft trued by small lathe. N. D. Jackson *679
Standard forms for turbine heat balance. E. V. Pollard.....*435
Three ways to support a condenser. A. J. Braun *790
Vibration cured. H. C. Bulsara..... 677

V

VALVES

Air-loaded valves for steadier pressures. E. H. McCarthy.....*503
Air receiver outdoors protected by cover. A. R. Ciotti..... 427
Avoid wrenches for valve operation. S. H. Coleman 272
Brass plates identify valves. S. H. Coleman 584
Burlington station, Public Service Electric & Gas Co., N. J. charts the way for motor-operated valves. S. D. Barr *900
Cap protests valve stem. S. H. Coleman.*685
Condenser valve operated by motor drive. H. M. Naylor.....*351
Crank control for blowoff valves. C. C. Lynde *917
Cure for leaky relief valve. J. T. Toposky *684
Dry ice a handy shrinker. H. P. King.. 683
Guard keeps water out of crankcase. S. M. Elonka.....*677
Homemade automatic float-valve control. Alex Gray.....*120
How to set piston valves. S. M. Elonka.*343
Limit improves valve operation. P. E. Meredeth *750
Motor-operated valves. C. W. Kuhn....*468
Multiple-control valves prevent water-hammer. O. M. Roberts..... 752
Plug cocks simplify valve hookup. R. Boettinger *685
Reconditioned gate valve disks and seats. Leslie Bradley.....*426
Shutdown from broken valve avoided. H. Moore *684
Too much clearance causes packing trouble. Alex Gray.....*582
Vacuum eliminates bearing-oil vapors. H. M. Naylor.....*836
Valve-rod repair. Alex Gray.....*682
Vector diagrams, how to use. Phil Swain.*916

W

WAR

Defense digest 413
Defense digest—trends, achievements, sidelight 491
Federal Power Commission reports basic data for defense power needs (tables & charts) 152
Help maintain source of supply. Phil Swain 692a
Let's be proud of the chance to do a man's work (Ed)..... 459
Long war or short? take your choice (Ed) 897
Operating engineers enlist for defense fire protection *423

Page

Power facilities (Ed)..... 305
Report on the defense situation.....*155
Wanted—inventions for defense. E. S. Smith *418

WATER POWER

Alcoa hydro plants to be operated by TVA 700c
American Society of Mechanical Engineers—hydraulic session *975
Austin Dam plant attains 93% efficiency with adjustable blade turbines. H. V. Terry *326
Boulder Dam hydro to have electrical brains *139
Boulder Dam storage for six years (chart) 267
Dnieperstroy Dam ruins.....*742
Federal Power Commission report analyzes installed water power.....698c
Federal Power Commission reports basic data for defense power needs (table & charts) 152
Federal Power Commission's proposed program of new hydro installations (table) 665
Grand Coulee Dam receives more funds.609a
Grand Coulee waterwheel generator....*183
Hydroelectric projects built or on order in the U. S. from June, 1940 to June, 1941 (table) 662
Location and capacity of all government hydro projects (map)..... 664
Overshot-waterwheel hydro plant built in Africa. W. B. West.....*574
Pickwick Landing plant of Tennessee Valley Authority—governing the Kaplan turbines. J. J. Ring.....*822
Report on turbine-governing problems (A.I.E.E. convention) *209
"Threading" the rotor into the stator..*262
U. S. Bureau of Reclamation proposed program of new steam and hydro installations (table) 691
United States leads world in hydro horsepower 375a
Water pressure, how to figure. Phil Swain.....pt. 1, *55; pt. 2, *129
Water treatment—L. H. Gilmer Co. installs aeration and filtration plant to clear piping of cooling-water system. Case & Alling.....*474

WELDING

Alameda station replaces corroded stack rings with welded..... *18
Bronze-welded bands safe-end cold chisels. H. H. Moss.....*198
Bronze welding cures leaky condenser. T. B. Jefferson.....*679
Clamp aligns pipe for welding. T. F. Leach *684
Copper arc welding repairs waterwheels. M. E. Bridston.....*752
Defense speeded by welding.....*492
Dollies for welding of split pipe sections. C. C. Lynde.....*585
Engine mended by welding. F. L. Berry *273
Eroded fan blade repaired by welding. A. H. Cuzner..... 670
High-pressure lines repaired by welding.*683
How to lap weld..... *56
How to make arc-welded steel cylinderheads. F. E. Ford.....*763
Million-volt x-ray speeds welded boiler production *597
Sabotaged ships repaired by welding...782b
Shaft bearing-journals repaired by welding 392
Six miles of welded piping in Cleveland municipal power plant.....*898
Upper head welded in vertical tubular boiler. A. G. Wiggins.....*835
When to weld for boiler repairs.....*114

WIND POWER

Hoisting the pintle girder atop Grandpa's Knob *414
Plant at Grandpa's Knob, near Rutland, Vt. *738
World's largest wind-turbine plant nears completion in Vermont...*337; *382
Wire rope, see Cables

X

X-rays—Million-volt x-ray speeds production of boiler drums.....*597

ADAMS, JAMES, JR. Pulley alignment makes flat belts run true, *577. Sweet-running belts require correct tension, *334.
Adams, Orville. Engines for locker-plant power, *593.
Addison, J. R. Purging ammonia system, 755.
Alimansky, M. I. Capacitors for power-factor improvement, pt. 1, *713; pt. 2, *793.
Allen, A. B. Easy-to-make muffler for diesel receiver, *678.
Allen, George J. Pipe cleaning, 276.
Alling, S. F. & R. Y. Case. Low-cost treatment rescues process cooling-water system, *474.
Anderson, C. R. Bypass helps clean strainer, *675. Hot makeup water reduces corrosion, *507. Stack inspection with binoculars, 120.
Annett, F. A. Mechanical power transmission, *89.
Armstrong, Leslie. Orifice in gage glass, 51.
Arnold, Paul W. Voltage control extends motor-speed adjustment, *178.
Atlas, R. Draft troubles, 833.

BACHMANN, CARL. Corrosion in cooling coils, 510. Diesel generators as synchronous condensers, 509. How to improve parallel pump operation, 754. How to synchronize with outside source of power, *354. How to ventilate, 909. Pump for cooler, 202. Pumps lose suction, 932a. Purging ammonia system, 773a.
Bailey, G. B. Diesel generators as synchronous condensers, *508.
Baker, B. P. Oil, oil-poor and oilless circuit breakers, *542.
Baker, M. D. Wanted—a new turbine oil test, *314.
Baldwin, C. W. Smoke troubles, 205.
Barr, S. D. Burlington charts the way for motor-operated valves, *900.
Barrett, George. Breakage of wedge bolt, 52. How to ventilate, 931a.
Baumeister, Theodore, Jr. Suction-discharge design aids fan performance, *286.
Bell, William W. Better method for finding true center, *513.
Bennett, A. L. Roller pipe support made by welding, *685. Oil circuit breakers operated in cascade, *839.
Bentley, Frank. Old V-belt makes lamp-cord support, *72c.
Berger, J. G. Exhaust steam conditions candy plant, *494.
Berry, F. L. Water cracks journal-bearing surface, 121. Welding repairs wrecked engine, *273.
Billings, R. O. Compressed air traces boiler leaks, *674. Stub tubes keep boilers working, *673.
Blessing, K. E. Pumps lose suction, *910.
Blum, George. More hp from steam engine, 126. Purging ammonia system, 756.
Blum, Samuel. Disston completes first step in power program, *730.
Boettinger, R. Electric drill cleans boilers, *673. Guides make job of hanging unit heaters easy, *24. Hole in check valve prevents freezing, *275. Lamp extension cord made more useful, *122. Lubrication cures packing troubles, *505. Make old packing protect the new, *279. Micrometer simplifies leveling job, *835. Plug cocks simplify valve hookup, *685. Poor contact causes electric-heater trouble, *914.
Boyer, Glenn C. Algona, Iowa, municipal electric-generating station diesel-plant layout, *786. Fundamentals of diesel cooling, *919. Practical methods of diesel heat recovery, *172.
Bradley, Leslie. Draft troubles, 833. Reconditioned gate valve disks and seats, *426. Smoke troubles, 223c. Threaded plug repairs diesel piston, *678.
Brandon, M. M. So you're puzzled about electric-conductor insulations, *496.
Braun, A. J. Three ways to support a condenser, *790.
Bridston, Mandus E. Copper-arc welding repairs waterwheels, *752. Water-cooled transformers changed to self-cooling, *834.
Bristol, E. S. Steam-pressure regulation by automatic control, *242.
Britt, W. H. More hp from steam engine, 126.
Brock, T. E. Returning condensate, 278.
Bromley, Charles H. What is quality in a lubricant? *131.
Bromley, Percy. Loose crank pin, *431.
Brown, H. D. Boilers, 607c. Draft troubles, 831. How to ventilate, 908. Pump for cooler, *204. Pumps lose suction, *911.
Brown, J. S., Jr. Removing water for fuel oil, 428.
Buckley, B. Y. Vacuum for emergency operation, *672.
Buitrago, E. M. Hoist handles transformer radiators, *199.
Bulsara, H. C. Troublesome turbine vibration cured, 677.
Burton, S. J. Breakage of wedge bolts, 69a.
Butcher, I. A. How to ventilate, 931a. Pumps lose suction, 933a.

CAMPBELL, H. A. F. Model maintenance schedule, *829.
Carey, J. P. Purging ammonia system, 773b.
Carroll, H. N. Private plants in Calif. are mainly motor drives, 71b.
Carter, F. W. Breakage of wedge bolt, 51. More hp from steam engine, 125.
Case, R. Y. & S. F. Alling. Low-cost treatment rescues process cooling-water system, *474.
Chamberlain, I. S. More hp from steam engine, *125.
Chandler, E. B. Boilers, 607c.
Cheatham, T. C. Troublesome oil leak stopped, 688. Turbine-bearing oil leak stopped, *689.
Ciotti, A. R. Install air receivers inside the plant, 198. Protect outdoor air receivers, *427.
Clark, Manley H. New facts on high-temperature gas-engine cooling, *515.
Cleary, H. P. Power threader uses die stocks, *350.
Clower, James I. Bearing lubrication of reciprocating air compressors, *390. Fires and explosions in compressed-air systems, 269. Gear teeth don't roll, 299b. Guide to better compressor lubrication, *734. Lubricating cylinders of reciprocating air compressors, *186. Rules for successful air-compressor operation, 201.
Coleman, S. H. Avoid wrenches for valve operation, 272. Boiler blow-down signal, *686. Booster pump increases spray-pond capacity, *507. Brass plates identify valves, 584. Cap protects valvestem, *685. Condensers cleaned by reversed water flow, *751. Fan power needs important consideration, 150c. Handy maintenance aid, 674. Preventing corrosion of pipe threads, 200. Spares for defense loads, 671.
Constable, P. C. Purging ammonia system, 755.
Corrigan, Brian. Breakage of wedge bolt, 52. Removing water from fuel oil, 429.
Corwin, Lloyd A. New boilers for World's largest malting company, *548.
Cummings, R. D. Troubles on 3 wire balancer sets, 273.
Cummings, R. F. Premeasured control pilots high-efficiency for Lansing Station, *74.
Cummings, R. O. Connection upsets load division, *425. Self-registering air-gap gage, *753. Separate conduits overheat insulation, 506.
Cunningham, T. F. Boilers, 588. Loose crank pin, *430.
Cuzner, A. H. Welding repairs eroded fan blade, *670.

DANZ, A. P. Coal-tower maintenance cut, 675.
deRosa, T. Loose crank pin, *430. Pointers on safety, 72a. Pump priming, 586. Returning condensate, 277.
Distelhorst, S. D. Locomotives supply temporary steam, 670. Locomotives supply temporary steam load, *506.
Doehne, G. V. Breakage of wedge bolts, *69b.
Donovan, Daniel. How to ventilate, 909. Loose crank pin, 430.
Doran, William. Reminiscences about the old chief, pt. 3, *21; pt. 4, *88; pt. 5, *185; pt. 6, *235; pt. 7, *321; pt. 8, *396; pt. 9, *493; pt. 10, *551; pt. 11, *739; pt. 12, *821; pt. 13, *899.
Downs, W. S. Orifice in gage glass, 50.
Drabelle, John M. Dew diesel plant Iowa's largest, *332. Practical ways to clean heat exchangers, *438.
Duff, E. J. Eliminates climb to safety valves, *279. Simple way to hold insulation in place, 72d.
Dulmage, W. W. & C. J. Walker. Performance test at Ford Motor Co., *476.
Dutcher, F. H. Is Warren Noble's idea really so new? 71c.

EDLUND, K. R., H. R. WILSON & G. H. VON FUCHS. Evaluating corrosion resistance of modern turbine, *162.
Edwards, R. G. The old chief's helpers are important, 128.
Elder, A. C. Loose crank pin, 431.
Elliott, I. S. Purging ammonia system, 756.
Elonka, S. M. Boiler-retubing job solved easily, *201. Easy-to-make oil cleaner, *689. Guard keeps water out of crankcase, *677. How to make and fit piston rings, *192. How to set piston valves, *343. Metal-disk strainer protects pump, *121. Pump-cylinder liners trued in a lathe, *46. Quick pipe-fitting repair, 685. Quick repair for broken pipe tee, *48. Shims around boiler tubes, *427. Sleeve stiffens small drills, *349. Stops condenser leaks with sawdust, *274. These drain nipples don't break off, *678. Wrench subdues tough nuts, *583.
Elwell, F. Removing water from engine flywheel pit, 134.
Equi, P. J. Boilers, 589. Pumps lose suction, 932c.
Estlick, W. T. Transformer corrects lighting trouble, *681.

FAULHAVER, F. V. Detecting invisible cracks in metal, 750.
Feller, E. W. How to synchronize with outside source of power, 355. Pump priming, 586.
Finch, C. A. Corrosion in cooling coils, 510.
Finch, V. C. Fans for air conditioning, *359.
Flickinger, E. D. Boiler-water recirculation cuts chemical costs, *841.
Flowers, H. E. More hp from steam engine, 125.
Flynn, Henry & J. D. Yoder. How an industrial topping plant treats feedwater, *554.
Fontaine, R. E. Piston-rod scraper stops oil leakage, *677. Plugged nozzle improves efficiency, 677.
Ford, Floyd E. How to make arc-welded steel cylinder-heads, *763.
French, Dudley K. Get a true sample first, *743.
Fuller, John L. Universal joints speed motor testing, *424.

GAFFERT, GUSTAF A. & F. V. SMITH. Reason behind the new University of Illinois plant, *322.
Garrett, Roy M. Feeding ash protects chain grades, *674.
Gaylord, W. W. Shavings make steam, *393.
Gibbons, J. O. G. Boilers, 608a. Crankpin loose in engine-generator, *352. Draft troubles, 832. How to ventilate, 910. Pump for cooler, *205. Pumps lose suction, 910. Removing condensate from a steam line, *149c. Returning condensate, 279.
Glenn, J. C. Lesson in geometry, 207.
Glenn, R. B. Why ac magnet coils may overheat, 48.
Godeke, R. H. Hints on burning natural gas, *560.
Gorrie, J. M. Aye, water is a powerful force, 357. Smoke trouble, 205.
Gozdenovich, M. Draft troubles, *833.
Grant, U. J. Orifice in gage glass, 51.
Gray, Alex. Double screen keeps water clean, *585. Homemade automatic float-valve control, *120. How to sharpen glass cutters, *46. Oil-ring scrapers stop bearing heating, *913. Quick repair for broken stuffing box, *682. Simple valve-rod repair, *682. Too much clearance causes packing trouble, *582. Vee-end chisel cuts cylinder liner, *750.
Greer, Anthony. Crankpin loose in engine-generator, *353. How to ventilate, 931a. Loose crankpin, 429. Pump for cooler, 223b. Reversed valve rod cures packing trouble, 912.
Grimshaw, Robert. How to become an expert, 207.
Griscom, S. B. How to protect motor and generator field coils, *33.
Grover, W. H. Smoke troubles, 224a.

HAGEN, C. O. Quick engine-frame repair, *676. Steam ejector from fittings, *585.
Haines, R. W. Has his own simplified level, *917.
Hanlon, Raymond T. Conductivity cell—now an operator's tool, *812.
Hanratty, Frank. Diesel generators as synchronous condensers, 509.
Hansen, S. S. Clean diesel oil lasts longer, pt. 1, *14; pt. 2, *78.
Hardy, G. M. Breakage of wedge bolt, 51.
Harvey, W. H. Purging ammonia system, 756.
Heinze, G. A. Breakage of wedge bolt, 51. Returning condensate, 279.
Hemenway, E. L. Operates small motor from large one, *834.
Hicks, Tyler G. Back in the days of the old chief, 288. Pump priming, 587. Removing water from fuel oil, *429.
Hodgson, H. W. Commutator connections caused sparking, 504. Correct polarity of commutating poles, *349. Defective motor causes lamps to flicker, 424. Defective pulley spoils commutator, 199. Millivoltmeter checks oil quality, 688. New key stops generator pounding, 425. Re-connection cures transformer troubles, *273. Reverse polarity on dc generator cured, *123. Shunt-field connections make a difference, 349. Undersize shaft wrecks large fan, 581. Wind overloads exhaust-fan motor, 275. Worn bearings reduce capacity, 582. Wrong connections unbalance voltage, *753.
Hoksch, Orville. Pumps repaired with metal spray, 685.
Holman, George. How to ventilate, 908.
Holmen, T. K. Chain and spring make simple pipe hanger, *837.
Honore, A. Rebuilt orifices cure burner trouble, *671.
Huffman, S. L. Roller bearing supports pipeline, *48.
Humphreys, C. G. & A. A. Markson. Volume-quality chart for steam, 441.

IRWIN, FRANK. Pumps lose suction, 931c. Purging ammonia system, 756.

JACKSON, N. D. Turbine shaft trued by small lathe, *679.
Jefferson, T. B. Bronze welding cures leaky condenser, *679. Convenient way to remove broken studs, *678.
Johns, George A. Miniature sulphur burner treats feedwater at Necco, *57.
Johnston, E. W. Improvement on cooling-water hookup, *513.
Jones, R. R. New plant saves $3,000 per month for Republic Rubber Company, *2.
Jones, W. W. Purging ammonia system, 755.
Julsrud, R. S. Boilers, 608a. How to reduce flyash, *127. Returning condensate, 279.

KARASSIK, IGOR J. High-pressure boiler-feed pumps, pt. 1, *159; pt. 2, *318. Pumps lose suction, 932b.
Keiffer, L. R. & D. M. Warren. Troubleshooting fluorescent lamps, *810.
Kennedy, W. M. Tight plugs for condenser tubes, 679.
Keough, Peter F. Steam jets for damaged stack, *671.
Kerstein, N. A. & R. C. Ulmer. Plastic covers eliminate panel-meter glare, *740.

(*) illustrated. (Ed) Editorial

King, H. P. Dry ice a handy shrinker, 683. Makeup water reduced 50%, 687. Piping change holds feed temperature, 687.
Knoll, William J., Jr. Comfortable drawing board, *350. Test keeps voltage regulators in shape, *681. How to keep from losing tools, *272.
Kristal, Frank A. Excessive speed causes pump troubles, 753. Motor pump applied to sump service, *915. Practical pumping pointers, *727. Pump boosts head and capacity, *682. Pump capacities at high temperatures, *123.
Kuhn, C. W. Motor operation simplies valve control, *468.

LANGE, H. W. Know fire—to put it out, out, *720.
Langworthy, R. A. Building an institutional power plant, *486.
Larson, L. M. Breakage of wedge bolt, 53.
Leach, T. F. Handy clamp aligns pipe for welding, *684.
LeQuesne, C. A. How to synchronize with outside source of power, 355. More hp from steam engine, 126.
Linde, C. C. Washout-plug clamp holds blowdown pipe, *351.
Low, F. R. Merry Christmas, 985.
Lym, J. H. Sagging boilers go straight, *761.
Lynde, Charles C. Crank control for blowoff valves, *917. Pipe sections make pipebending devise, *425. Split pipe sections make welding dollies, *585. Water cooling keeps compressor operating, *585. Wire-rope guys cure vibration, *349.

MADDOCK, BILL. Fixing method speeds oxygen test, *686.
Maher, James F. Oil cup solves lubrication problems, *689. Portable work bench built by welding, *583.
Mandeville, C. G. Breakage of wedge bolt, 53.
Marjie, James & Holford Thorns. Beveling pipe with portable machine, *274.
Markland, A. R. How to synchronize with outside source of power, 379a. Transformer changes save power, *680.
Markson, A. A. & C. G. Humphreys. Volume-quality chart for steam, 441.
Marsh, T. A. Test shows small-unit efficiency, *923.
Mathews, R. T. & G. R. Rich. Watts Bar steam plant to be on line 18 months after authorization, *843.
Maubury, R. E. Capacitors save $6,900 in one year's operation, *504.
McBurney, R. J. How to ventilate, *909.
McCarthy, E. T. Air-loaded valves for steadier pressures, *503.
McDonald, R. C. How to improve parallel pump operation, 755. Pump for cooler, *202. Pump priming, 587. Pumps lose suction, 931c.
McGrath, William A. Gear rotary pumps, *552.
McNally, George. Boilers, 588. How to improve parallel pump operation, 754. How to ventilate, 909. More hp from steam engine, 125. Purging ammonia system, 755.
Melas, William. Accurate measurement of pulsating flow, *379c.
Meredith, P. E. Better visibility for gage-glasses, *582. Easy test for radiator traps, *912. Formula for operating results, *420. Limit improves valve operation, *750.
Metz, George. Quiet, please! *723.
Miles, O. C. Add safety to babbitt ladle, *501.
Mingle, J. G. Selecting chimney size for natural draft, *283. Moore, H. Shutdown from broken valve avoided, *684.
Morgan, A. J. How to detect and cure wire-rope troubles, pt. 1, *81; pt. 2, *169.
Moss, H. H. Bronze-welded bands safe-end cold chisels, *198.
Mullen, W. T. Draft troubles, *832. Orifice in gage glass, 51. Pump priming, 588. Removing water from fuel oil, *428. Returning condensate, 277.
Munson, H. O. Easily made lube-oil reclaimer for the diesel plant, *749. Wringer saves oil and oily waste, *914.

NAYLOR, H. M. Orsat on wheels speeds boiler tests, *673. Power drive eases valve operation, *351. Pump for cooler, *203. Removing water from fuel oil, 428. 20 cents a week protects standby boiler, *386. Vacuum eliminates bearing-oil vapors, *836.
Newell, F. M. Returning condensate, 278.
Noiles, G. D. How to synchronize with outside source of power, 355.
Norman, Earl E. Indicator for bearing temperatures, 134.

OBRIEN, R. J. Crankpin loose in engine-generator, 353.
Oliver, R. C., Jr. Owensboro municipal-designed for $1 coal, *415.
Olsen, G. K. Pattern for glass disks, 584.
Olson, D. C. Blowpipe removes armature insulation, *47.
Oswald, J. D. Insulated oil-pipe joint stops sludging, *688.
Oswald, T. D. Concrete casing keeps pump going, 683. Tin cans, glass tubes make draft gages, *505.

PARKINSON, H. More hp from steam engine, 124.
Pate, M. T. Easily made guard protects V-belts, *49. Flexible mounting increases lamp life, *584. Grille protects pump lubricator, *122. Multiple muffler exhaust noise, *676. Safety cross-over for hot pipes, *915.
Pef, N. T. Boiler converted into an economizer, *49. Orifice in gage glass, 50. Parallel pump operation, 917. Water column sampling? *929a.
Petrik, E. T. Magnetic variable-speed drives control boiler draft, *801.
Pincus, L. I. Improved pH test for boiler water, 582.
Platt, John. Piping change improves valve operation, *683.
Pollard, E. V. Standard form for turbine heat balance, *435.
Powers, R. E. Rubber mountings correct meter readings, *581.
Pugsley, W. H. Draft gages for boiler auxiliaries, pt. 1, *44; pt. 2, *118; pt. 3, *268.

REA, N. L. Putting micrometer precision into machine leveling, *580.
Rea, T. H. Purging ammonia system, 756.
Redd, John C. Quick motor change prevents water shortage, *922.
Redman, G. W. Breakage of wedge bolt, 53.
Relief, W. Belt alignment, 831.
Rettaliata, Dr. J. T. Portable power from gas turbines, *266.
Rich, G. R. & R. T. Mathews. Watts Bar steam plant to be on line 18 months after authorization, *843.
Ring, J. J. Governing the Pickwick Landing hydro turbines, *822.
Roberts, E. A. Diesel generators as synchronous condensers, 508. How to synchronize with outside source of power, 354.
Roberts, O. M. Auxiliary chute keeps pulverizer in service, *507. Multiple-control valves prevent water-hammer, 752.
Rogers, Louis A. Color comes to Lincoln Park, 184.
Rossnagel, W. Elwood. Fighting power-plant fires, pt. 1, *804. How to tie knots, *591. How to make hitches, *759. Safety standards for fixed steel ladders, *28. Safety standards for operating platforms, *329. Standard stairs aid safety, *166.
Rowley, L. N. Heating, *245.
Rushenberg, Harold. Breakage of wedge bolt, 53.

SAMS, G. E. Truth about floats, 72b.
Sanders, J. L. Purging ammonia system, 756.
Schenk, Erich. How to ventilate, 930a. Pump priming, 587.
Schmidt, F. A. Pumps lose suction, 933a.
Schmoker, E. O. How to synchronize with outside source of power, 379b.
Schnoll, Nathan. Warning light indicates carryover in steam, *348.
Schubert, Fred. Operating tips on open feedheaters, *346.
Schweer, J. H. Crankpin loose in engine-generator, *353.
Schweitzer, P. H. How to make a simple diesel smoke meter, *800.
Sermon, R. C. Boiler explosion facts and fallacies, *270.
Simons, J. P. Draft troubles, 832. Purging ammonia system, 756.
Skougor, L. H. Motor follows motion of countershaft pulley, *200.
Smart, Frank. Filter removes oil from exhaust, *686. Ladder for safe access to boiler drums, *913.
Smith, A. R. & E. S. Thompson. Mercury unit sets efficiency record, *236.
Smith, E. S. Wanted—inventions for defense, *418.
Smith, Frank V. & G. A. Gaffert. Reasons behind the new University of Illinois plant, *322
Smith, George I. Add loud horns to plant-phone system, *915. Pilot gage for base-load operation, 751.
Smith, O. K. & G. T. Williams. Conductance measurement of condensate solids, *189.
Smith, S. O. Ammeter connections on 3-wire generators, *275.
Sogard, R. H. Emergency lights from control battery, *680.
Spencer, G. A. Breakage of wedge bolt, 52.
Spielvogel, S. W. Model test checks pipe-stress calculation, *716. Stress calculation for high-temperature piping, pt. 1, *12; pt. 2, *85.
Spring, Harry M. Cooling-water failure gives alarm, *426. How to find center of a circular plate, *47. Why watertube boilers bulge, *906. Repair for cracked boiler head, *675. Telltale holes test pressure-vessels for corrosion, *196.
Spurck, R. M. Breakers blast circuits open, *9.
Starkweather, W. L. Boiler-water concentration can be too low, *724.
Sterrett, Elton. Corrosion in cooling coils, *509. Skimming pool improves cooling-tower, *676.
Stevenson, A. E. Crankpin loose in engine generator, *352.
Stewart, B. R. Belt alignment, *830. Indicating ammeter prevents motor overloads, 914. Low voltage causes motor trouble, 350. Reel takes up lamp-cord slack, *122.
Stocker, F. L. Smoke troubles, 223c.
Stossel, Otto E. It takes more steam to heat small hotels, *502.
Summers, R. E. What CO_2 is best? *571.
Sumner, V. C. How to reduce flyash, 127.
Sutcliffe, A. G. Important factors in buying fans, 72b.
Swain, Philip W. Electrical machine solves heat-transfer problems, *480. Figuring efficiency, *356. Figuring orifices, *206. Figuring steam-engine efficiency, *432. Figuring water heating, *512. Figuring water pressure, *129. Help maintain source of supply, 692a. How heat moves, pt. 1, *758; pt. 2, *838. How to figure heat mixtures, *590. How to figure pressures, pt. 1, *55; pt. 2, *129. How to sketch, *825. How to use vector diagrams, *916. More about flow measurement, *280. Short cuts in combustion, *499.

TERRY, R. V. Adjustable-blade turbines attain 93% efficiency, *326. New pumps cut power costs in half, *22.
Thompson, E. S. & A. R. Smith. Mercury unit sets efficiency record, *236.
Thorns, Holford & James Marjie. Beveling pipe with portable machine, *274.
Thornton, B. M. More about metal-wall thickness, *780b.
Topolosky, John T. Cure for leaky relief valve, *684.
Totten, J. M. Crankpin loose in engine generator, *353.
Trail, Thomas. Holder keeps tools handy, *584.
Tufft, J. M. Pipe cleaning, 277.

ULMER, R. C. & N. A. KERSTEIN. Plastic covers eliminate panel-meter glare, *740.

VAN DEURSEN, C. A. Bottom lighting spots water level, *671.
Van Orden, Paul W. Longer life from conveyor belts, *339.
Van Wingen, P. M. Curing cranky crankpin, *837.
Von Fuchs, G. H., N. B. Wilson & K. R. Edlund. Evaluating corrosion resistance of modern turbine oils, *162.
Vonachen, E. J. How to figure steam-engine drive, *595.

WADSWORTH, F. L. Quicker way of figuring heating capacity, 72a.
Waldo, Hollis T. Tests show effect of suction head on condensate pumps, *483.
Walker, C. J. & W. W. Dulmage. Performance test at Ford Motor Co., *476.
Ward, P. How to improve parallel pump operation, 754.
Warner, W. E. Shellac and tape protect rubber hose, 834.
Warren, Dean M. & L. R. Keiffer. Trouble-shooting fluorescent lamps, *810.
Warrington, K. R. Three years' experience with modern wood-waste-burning system, *37.
Waterman, Alvan L. How to synchronize with outside source of power, *354. Steel rings make unruly governor behave, 677.
Watson, John E. Dust collectors put old stacks to work, *815.
Webber, L. E. Basic facts on wood burning, *156. Furnaces for wood burning, *471.
Wiechmann, F. Breakage of wedge bolt, 51.
Weisberg, H. Burlington Station adds 100,000 kw. condensing unit, *460.
Wellhofer, Ernest. Hand rule simplifies rope reeving on drum, *501.
West, W. B. Adventure of an engineer—pioneering in Africa, *574.
White, George T. From junk pile to pipe-threading machine, *837.
Wiggins, A. G. Upper head welded in vertical tubular boiler, *835.
Willey, Charles H. Quick-change handle for blade tools, *46. Splash-dipper cures bearing trouble, *688. Tin can makes small parts tray, *201. Tool speeds valve operation, *72d. Wood block for punch work, *913.
Williams, G. T. & O. K. Smith. Conductance measurement of condensate solids, *189.
Wilson, Gilbert M. Automatic pump-pressure regulator, *683. Blowdown control at boiler front, *584. Flywheel marking aids gas-engine starting, *424. Lubricating-oil heater, *836. Multiple muffler reduces engine exhaust noise, *506. Oil reservoir for emergency lubrication, *425. Plate simplifies installation work, *751. Warmed butane line saves fuel costs, *504.
Wilson, James. How to synchronize two power systems, 695a.
Wilson, N. B., G. H. Von Fuchs & K. R. Edlund. Evaluating corrosion resistance of modern turbine oils, *162.
Wood, Thomas. Armature core welded to spider, *272. Cooling water does triple duty, *345. Quick repair of armature core, *680. Simple control improves sump-pump operation, *121.
Woodruff, R. B. Jointless square-tubular busbars improve distribution efficiency, *240.
Woods, G. I. Breakage of wedge bolt, 53.
Wooley, John F. Simple scheme cuts heating costs, *117.
Wright, E. F. Pumps lose suction, 931b.
Wyrough, C. J. Breakage of wedge bolt, 52. Loose crank pin, *430. Pump for cooler, *203.

YODER, JOSEPH D. & HENRY FLYNN. How an industrial topping plant treats feedwater, *554.

ZETTERQUIST, E. More kw. from old turbines, *710.

(*) illustrated. (Ed) Editorial